

Drinking water Sampling and Analysis for Lead (Pb)

Codes for sampling points.

WC = water cooler (chiller unit)

CF = classroom faucet

KC = kitchen faucet, cold

EC = home economics room, cold

EH = home economics room sink, hot

NS = nurse's office sink

SC = service connector

BR = bathroom sink

LR = Locker Room

DF = Drinking Fountain

BDL = Below Detection Limits

[Does not mean the sample is lead-free]

School District Name: Baldwinsville CSD

Date: 9/27/2016

Building Name: Palmer

Total No. Samples: 53

Sample No.	Description	Date/Time Sampled	Location of Water Outlet	Type of Outlet (i.e. sink, DF)	Notes	Lead Conc. (ppb)
Palmer-1	First Draw	5:35 AM	Girls Locker Rm	BR	Sink A	4.5
Palmer-2	First Draw	5:35 AM	Girls Locker Rm	BR	Sink B	4.7
Palmer-3	First Draw	5:36 AM	Boys Locker Rm	BR	Sink A	8.9
Palmer-4	First Draw	5:36 AM	Boys Locker Rm	BR	Sink B	7.4
Palmer-5	First Draw	5:38 AM	A110	KC		3.5
Palmer-6	First Draw	5:38 AM	A110	BR		1.0
Palmer-7	First Draw	5:39 AM	A108	KC		<1.0
Palmer-8	First Draw	5:40 AM	A108	BR		<1.0
Palmer-9	First Draw	5:40 AM	A110	KC		<1.0
Palmer-10	First Draw	5:41 AM	A110	BR		<1.0
Palmer-11	First Draw	5:42 AM	NEAR A106	CF		<1.0
Palmer-12	First Draw	5:43 AM	C101	CF		<1.0
Palmer-13	First Draw	5:44 AM	C103	CF		<1.0
Palmer-14	First Draw	5:45 AM	C105	CF		<1.0
Palmer-15	First Draw	5:46 AM	c107	CF		<1.0
Palmer-16	First Draw	5:47 AM	C107	BR		<1.0
Palmer-17	First Draw	5:47 AM	C109	CF		<1.0
Palmer-18	First Draw	5:48 AM	C109	BR		<1.0
Palmer-19	First Draw	5:49 AM	C110	CF		<1.0
Palmer-20	First Draw	5:50 AM	C108	CF		<1.0
Palmer-21	First Draw	5:50 AM	C106	CF		<1.0

Palmer-22	First Draw	5:51 AM	C104	CF		<1.0
Palmer-23	First Draw	5:52 AM	C102	CF		<1.0
Palmer-24	First Draw	5:52 AM	B104	BR		<1.0
Palmer-25	First Draw	5:54 AM	B101	BR	SINK A	1.1
Palmer-26	First Draw	5:54 AM	B101	BR	SINK B	<1.0
Palmer-27	First Draw	5:54 AM	B101	BR	SINK C	<1.0
Palmer-28	First Draw	5:57 AM	B105	BR	SINK A	1.3
Palmer-29	First Draw	5:57 AM	B105	BR	SINK B	1.3
Palmer-30	First Draw	5:57 AM	B105	BR	SINK C	1.5
Palmer-31	First Draw	6:06 AM	B107	CF		<1.0
Palmer-32	First Draw	6:07 AM	B109	CF		<1.0
Palmer-33	First Draw	6:08 AM	B111	CF		<1.0
Palmer-34	First Draw	6:09 AM	B113	CF		1.1
Palmer-35	First Draw	6:10 AM	B115	CF		<1.0
Palmer-36	First Draw	6:11 AM	B116	CF		<1.0
Palmer-37	First Draw	6:12 AM	B216	CF		2.9
Palmer-38	First Draw	6:13 AM	B215	CF		1.6
Palmer-39	First Draw	6:15 AM	B212	CF		13.0
Palmer-40	First Draw	6:16 AM	B210	CF		9.6
Palmer-41	First Draw	6:17 AM	B211	CF		<1.0
Palmer-42	First Draw	6:18 AM	B208	CF		11.0
Palmer-43	First Draw	6:19 AM	B209	CF		3.6
Palmer-44	First Draw	6:19 AM	B206	CF		5.7
Palmer-45	First Draw	6:20 AM	B207	CF		<1.0
Palmer-46	First Draw	6:20 AM	B202B	BR		4.3
Palmer-47	First Draw	6:22 AM	B205	BR	SINK A	2.7
Palmer-48	First Draw	6:22 AM	B205	BR	SINK B	3.0
Palmer-49	First Draw	6:22 AM	B205	BR	SINK C	<1.0
Palmer-50	First Draw	6:24 AM	B201	BR	SINK A	2.7
Palmer-51	First Draw	6:24 AM	B201	BR	SINK B	<1.0
Palmer-52	First Draw	6:24 AM	B201	BR	SINK C	<1.0
Palmer-53	First Draw	6:26 AM	B112	CF		<1.0