

## Drinking water Sampling and Analysis for Lead (Pb)

### Codes for sampling points.

WC = water cooler (chiller unit)

CF = classroom faucet

KC = kitchen faucet, cold

EC = home economics room, cold

EH = home economics room sink, hot

NS = nurse's office sink

SC = service connector

DF = Drinking Fountain

BDL = Below Detection Limits

[Does not mean the sample is lead-free]

School District Name: Baldwinsville CSD

Date: 4/6/2016

Building Name: Ray Middle School

Total No. Samples: **40**

Sample No.	Description	Time Sampled	Location of Water Outlet	Type of Outlet (i.e. sink, DF)	Notes	Lead Conc. (ppb)	Retest Results [Pb] (ppb)
1	First Flush	5:29 AM	Kit. KC nr. Cooler	KC		11.0	
1a	30- sec. draw	5:30 AM	"			1.9	
2	First Flush	5:36 AM	Room 231	DF		<b>24.0</b>	9 (1/13/17)
2a	30- sec. draw	5:37 AM	"	DF		5.7	
3	First Flush	5:41 AM	Boys Lckr Rm.			BLD	
3a	30- sec. draw	5:42 AM	"			1.2	
4	First Flush	5:46 AM	Nurse's Off.	KC		9.1	
4a	30- sec. draw	5:47 AM	"	"		BLD	
5	First Flush	5:49 AM	Hall nr. Cust. Off	DF	Left side	6.8	
5a	30- sec. draw	5:50 AM	"	"	"	1.6	
6	First Flush	5:52 AM	Hall nr. Cust. Off	DF	Right Side	3.9	
6a	30- sec. draw	5:53 AM	"	"	"	1.3	
7	First Flush	5:56 AM	Main Off.	KC		6.0	
7a	30- sec. draw	5:57 AM	"	"		1.1	
8	First Flush	5:59 AM	Girl's Lckr	DF		BLD	
8a	30- sec. draw	6:01 AM	"			1.2	
9	First Flush	6:03 AM	hall nr. 285	DF	Left side	BLD	
9a	30- sec. draw	6:03 AM	"	"	"	BLD	
10	First Flush	6:06 AM	hall nr. 285	DF	Right Side	BLD	

10a	30- sec. draw	6:06 AM	"	"	"	BLD	
11	First Flush	6:08 AM	Rm. 189	KC		4.7	
11a	30- sec. draw	6:09 AM	"	"		BLD	
12	First Flush	6:11 AM	Hall nr. 168	DF	nr. Girls lav	BLD	
12a	30- sec. draw	6:12 AM	"	"	"	BLD	
13	First Flush	6:14 AM	Hall nr. 169	DF	nr. Boys lav	BLD	
13a	30- sec. draw	6:15 AM	"	"	"	1.2	
14	First Flush	6:18 AM	Rm. 144	KC		10.0	
14a	30- sec. draw	6:19 AM	"	"		5.2	
15	First Flush	6:21 AM	Rm. 139 A	KC		<b>26.0</b>	12 (6/9/16)
15a	30- sec. draw	6:22 AM	"	"		3.2	
16	First Flush	6:23 AM	Hall nr. 142	DF	Boys	BLD	
16a	30- sec. draw	6:24 AM		"	"	BLD	
17	First Flush	6:26 AM	Hall nr. 143	DF	Girls	BLD	
17a	30- sec. draw	6:27 AM	"	"	"	BLD	
18	First Flush	6:29 AM	Rm. 122	KC		5.6	
18a	30- sec. draw	6:30 AM	"	"		BLD	