

## Drinking water Sampling and Analysis for Lead (Pb)

### Codes for sampling points.

BS = Bathroom Sink

WC = water cooler (chiller unit)

CF = classroom faucet

KC = kitchen faucet, cold

EC = home economics room, cold

EH = home economics room sink, hot

NS = nurse's office sink

SC = service connector

**School District Name:** Baldwinsville CSD

**Building Name:** Reynolds Elementary

**Total No. Samples:** \_\_\_\_\_

Sample No.	Description/Location	Date/Time Sampled	Type of Outlet (i.e. sink, DF)	Lead Conc. (ppb)	March 22, 2017 Retest - Lead Conc. (ppb)	April 12, 2017 Retest - Lead Conc. (ppb)	Sept 13, 2017 Retest - Lead Conc. (ppb)
REY-1	Boys Lav Café - BS	9-28-16/6:42 A	BS	2.8			
REY-2	Girls Lav Café - BS	6:43 AM	BS	BDL			
REY-3	Rm 108	6:49 AM	CF	9.1			
REY-4	Rm 103A	6:48 AM	CF	BDL			
REY-5	Rm.105 girls RR - A	6:49 AM	BS	BDL			
REY-6	Rm.105 girls RR -B	6:50 AM	BS	1.2			
REY-7	Rm.105 girls RR _ C	6:50 AM	BS	BDL			
REY-8	109 Boys RR A	6:53 AM	BS	BDL			
REY-9	109 Boys RR B	6:52 AM	BS	BDL			
REY-10	109 Boys RR C	6:54 AM	BS	BDL			
REY-11	Rm 112	6:56 AM	CF	51	31	24	13
REY-12	Rm 124	6:57 AM	CF	9			
REY-13	Rm 126	7:01 AM	CF	34	620	28	180
REY-14	Rm 128	7:03 AM	CF	25	260	29	10
REY-15	Rm 117	7:04 AM	CF	2.8			
REY-16	Rm 132	7:05 AM	CF	3.1			
REY-17	Rm 134	7:07 AM	CF	4			
REY-18	RM 136	7:08 AM	CF	1.1			
REY-19	Rm 123	7:10 AM	CF	5		2.1	
REY-20	Rm 138	7:11 AM	CF	BDL			
REY-21	Rm 125	7:13 AM	CF	3.9			
REY-22	Rm 140	7:14 AM	CF	4.9			
REY-23	Rm 127	7:14 AM	CF	2.5			
REY=24	Rm 142	7:14AM	CF	4.9			
REY-25	Rm 129	7:15AM	CF	2.6			
REY-26	Rm 144	7:16 AM	CF	6.7			

REY-27	Rm 131	7:17 AM	CF	9.5			
REY-28	RM 146	7:18 AM	CF	7.9			
REY-29	Rm 146	7:19 AM	BS	1.7			
REY-30	Rm 148	7:20 AM	CF	7.3			
REY-31	Rm 148	7:20 AM	BS	3.1			
REY-32	Rm 150	7:21 AM	CF	9.1			
REY-33	Rm 150	7:21 AM	BS	3.9			
REY-34	OT/PT	7:22 AM	BS	7.9			
	RM 123		DF	16	20	28	23**

\*\* Removed Bubbler